

Educational Institutions Accessibility Checklists

Issued by: WORLD DISABILITY UNION (WDU)

Applicable Standards Universal Design Principles

Each checklist below is **independent**, has a **separate title**, and applies a **five-point evaluation system** for accreditation purposes.

Five-Point Evaluation Scale (Applicable to All Checklists)

Score	Description
1	Not available
2	Available but non-compliant
3	Partially available
4	Available and compliant with minor remarks
5	Fully available and fully compliant

I. Kindergarten Accessibility Checklist (Nursery / Preschool)

1. Accessible Parking

- Designated accessible parking spaces (minimum 5%)
- Located near main entrance
- Clear signage and markings

Score: /5

2. Curb Ramps & External Routes

- Step-free pedestrian routes
- Maximum slope 1:12
- Slip-resistant surfaces

Score: /5

3. Entrance Ramps & Doors

- Step-free entrance access
- Ramp handrails both sides
- Door clear width ≥ 90 cm

Score: /5

4. Internal Corridors

- Minimum width 150 cm
- Obstacle-free circulation

Score: /5

5. Emergency Exits & Alarms

- Accessible emergency exits
- Audible and visual alarm systems
- Exit ramps provided

Score: /5

6. Accessible Restrooms

- Child-appropriate accessible toilets
- Grab bars and safety fixtures

Score: /5

7. Inclusive Play Areas

- Accessible playground equipment
- Shock-absorbing surfaces

Score: /5

8. Autism-Friendly Spaces

- Quiet sensory-friendly room
- Visual communication aids

Score: /5

9. Wayfinding & Signage

- Child-friendly pictograms

- High-contrast signage

Score: /5

10. Additional Support Services

- Trained staff
- Emergency evacuation chairs

Score: /5

II. School Accessibility Checklist (Primary / Secondary)

1. Accessible Parking

- Designated accessible parking spaces
- Safe drop-off zones

Score: /5

2. Curb Ramps & External Routes

- Continuous accessible routes
- Proper slopes and widths

Score: /5

3. Entrances, Doors & Corridors

- Step-free access
- Door clear width ≥ 90 cm
- Corridors ≥ 150 cm

Score: /5

4. Elevators (Multi-Story Buildings)

- Wheelchair-accessible elevators
- Audible and visual indicators

Score: /5

5. Emergency Exits, Stairs & Evacuation

- Accessible emergency exits
- Evacuation chairs available
- Exit ramps and signage

Score: /5

6. Alarm Systems

- Audible and visual alarms

Score: /5

7. Accessible Restrooms

- Accessible toilets on each floor

Score: /5

8. Classrooms & Laboratories

- Accessible desks and layouts
- Accessible laboratory stations

Score: /5

9. Sports Facilities & Playgrounds

- Accessible sports fields
- Inclusive playgrounds

Score: /5

10. Transportation (School Buses)

- Accessible buses with lifts or ramps
- Designated wheelchair spaces

Score: /5

11. Cafeteria & Service Counters

- Accessible seating and counters

Score: /5

12. Prayer Room & Rest Areas

- Accessible routes and seating

Score: /5

13. Autism-Friendly Facilities

- Quiet rooms
- Visual schedules and guidance

Score: /5

14. Wayfinding & Signage

- Clear directional signage
- Braille/tactile signs where applicable

Score: /5

15. Additional Services

- Trained staff
- Accessibility policy

Score: /5

III. University Accessibility Checklist

1. Accessible Parking & Campus Routes

- Accessible parking across campus
- Continuous accessible pathways

Score: /5

2. Entrances, Doors & Corridors

- Step-free access
- Wide doors and corridors

Score: /5

3. Elevators & Vertical Circulation

- Accessible elevators in all buildings
- Emergency communication systems

Score: /5

4. Emergency Exits & Evacuation

- Accessible exits and ramps
- Evacuation chairs provided

Score: /5

5. Alarm Systems

- Audible and visual alarms campus-wide

Score: /5

6. Accessible Restrooms & Showers

- Accessible restrooms on each floor

Score: /5

7. Lecture Halls & Classrooms

- Wheelchair seating spaces
- Companion seating

Score: /5

8. Laboratories & Research Centers

- Accessible lab benches and equipment

Score: /5

9. Sports Facilities & Stadiums

- Accessible sports halls
- Wheelchair seating in stands

Score: /5

10. Swimming Pools & Changing Rooms

- Pool lifts or ramp access
- Accessible changing rooms

Score: /5

11. Transportation (University Buses)

- Accessible buses and stops

Score: /5

12. Cafeterias & Service Counters

- Accessible seating and counters

Score: /5

13. Prayer Rooms & Rest Areas

- Accessible prayer rooms

Score: /5

14. Autism-Friendly Areas

- Sensory-friendly rooms
- Clear visual guidance

Score: /5

15. Wayfinding & Signage

- Campus-wide accessible signage

Score: /5

16. Additional Services

- Disability support unit
- Assistive equipment availability

Score: /5

Accreditation

Institutions meeting requirements are eligible for:

- **WDU Accessibility Certification**
- Public recognition as an **Accessible Educational Institution**

This document is officially issued by the WORLD DISABILITY UNION (WDU) for inspection, evaluation, and accreditation of educational institutions.

Educational Institutions Accessibility Inspection Forms (Detailed)

Issued by: WORLD DISABILITY UNION (WUPD)

Applicable Standards: ADA / ISO 21542 / Universal Design Principles

Each form below is **independent**, has a **separate title**, and applies a **five-point detailed evaluation system** for accreditation purposes.

I. Kindergarten Accessibility Inspection Form

General Information

- Kindergarten Name:
- Address / Location:
- Inspector Name:
- Inspection Date:

Checklist

Item	1 Point	2 Points	3 Points	4 Points	5 Points	Remarks
Accessible parking (minimum 5%)	Not available	Non-compliant	Partially available	Available with minor issues	Fully compliant	
Curb ramps & external routes	Not available	Non-compliant	Partially available	Available with minor issues	Fully compliant	
Entrance ramps & doors	Not available	Non-compliant	Partially available	Available with minor issues	Fully compliant	
Internal corridors	Not accessible	Narrow or obstacle	Partially accessible	Mostly accessible	Fully accessible	
Emergency exits & alarms	Not available	Non-compliant	Partial coverage	Mostly compliant	Fully compliant	
Accessible restrooms	Not available	Non-compliant	Partially accessible	Accessible with minor issues	Fully accessible	
Inclusive playgrounds	Not available	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Autism-friendly spaces	Not available	Non-compliant	Partial provisions	Mostly compliant	Fully compliant	
Wayfinding & signage	Not available	Non-compliant	Partial coverage	Mostly compliant	Fully compliant	

Item	1 Point	2 Points	3 Points	4 Points	5 Points	Remarks
Additional support services	Not available	Non-compliant	Partial availability	Mostly compliant	Fully compliant	

Total Points: /50

Inspector Signature:

II. School Accessibility Inspection Form

General Information

- School Name:
- Address / Location:
- Inspector Name:
- Inspection Date:

Checklist

Item	1 Point	2 Points	3 Points	4 Points	5 Points	Remarks
Accessible parking & drop-off zones	Not available	Non-compliant	Partially available	Mostly accessible	Fully accessible	
Curb ramps & external routes	Not available	Non-compliant	Partially available	Mostly accessible	Fully accessible	
Entrances, doors & corridors	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Elevators (multi-story)	Not available	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Emergency exits, stairs & evacuation	Not available	Non-compliant	Partial provision	Mostly compliant	Fully compliant	
Alarm systems	Not available	Non-compliant	Partial coverage	Mostly compliant	Fully compliant	
Accessible restrooms	Not available	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Classrooms & laboratories	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	
Sports facilities & playgrounds	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Transportation (school buses)	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	

Item	1 Point	2 Points	3 Points	4 Points	5 Points	Remarks
Cafeteria & service counters	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Prayer room & rest areas	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Autism-friendly facilities	Not available	Non-compliant	Partial provision	Mostly compliant	Fully compliant	
Wayfinding & signage	Not available	Non-compliant	Partial coverage	Mostly compliant	Fully compliant	
Additional services	Not available	Non-compliant	Partial provision	Mostly compliant	Fully compliant	

Total Points: /75

Inspector Signature:

III. University Accessibility Inspection Form

General Information

- University Name:
- Address / Location:
- Inspector Name:
- Inspection Date:

Checklist

Item	1 Point	2 Points	3 Points	4 Points	5 Points	Remarks
Accessible parking & campus routes	Not available	Non-compliant	Partially available	Mostly accessible	Fully accessible	
Entrances, doors & corridors	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	
Elevators & vertical circulation	Not available	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Emergency exits & evacuation	Not available	Non-compliant	Partial provision	Mostly compliant	Fully compliant	
Alarm systems	Not available	Non-compliant	Partial coverage	Mostly compliant	Fully compliant	
Accessible restrooms & showers	Not available	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Lecture halls & classrooms	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	
Laboratories & research centers	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	

Item	1 Point	2 Points	3 Points	4 Points	5 Points	Remarks
Sports facilities & stadiums	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	
Swimming pools & changing rooms	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Transportation (university buses)	Not accessible	Non-compliant	Partially accessible	Mostly accessible	Fully accessible	
Cafeterias & service counters	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	
Prayer rooms & rest areas	Not accessible	Non-compliant	Partial provision	Mostly accessible	Fully accessible	
Autism-friendly areas	Not available	Non-compliant	Partial provision	Mostly compliant	Fully compliant	
Wayfinding & signage	Not available	Non-compliant	Partial coverage	Mostly compliant	Fully compliant	
Additional services	Not available	Non-compliant	Partial provision	Mostly compliant	Fully compliant	

Total Points: /80

Inspector Signature:

These detailed inspection forms are officially issued by the WORLD DISABILITY UNION (WDU) for field inspection and accreditation of educational institutions.